

Daily System Generation Summary on Thursday

Thursday, November 18, 2021

Availability at Daily Maximum Demand Hour

ST-Coal	0 MW
ST-Gas	0 MW
ST-Oil	0 MW
Hydro	2,497 MW
Distillate	0 MW
Total TNB	2,497 MW
Total IPP	15,092 MW
Total Co-Gen	0 MW
Total System	20,432 MW

Generation Mix

Type	MWh	Percentage
Hydro	16,656	4.58 %
Gas	37,963	10.43 %
Total TNB	54,619	15.01 %
ST-Coal	199,541	54.83 %
LSS	2,327	0.64 %
Gas	106,143	29.17 %
Total IPP	308,011	84.64 %
Co-Gen	932	0.26 %
Total Co-Gen	932	0.26 %
Total Generation	363,562	99.90 %
PLTG	341	0.09 %
HVDC	-701	-0.19 %
Interconnection	-360	-0.10 %
Net Energy	363,922	100.00 %

Maximum Demand Record

Date: 3/10/2020	18,808 MW
Date: 3/10/2020	394,238 MWH

Set On Bus, TNB, IPP And MD

Daily Maximum Demand Hour at:	15:00:00 Hour
Total Set On Bus	18,302 MW
TNB Generation	3,045 MW
IPP Generation	13,937 MW
Spinning Reserve	1,285 MW
Maximum Demand	17,055 MW
Net Energy	363,922 MWH
Load Factor	88.91 %

Fuel Cost

Total Cost:	76,578,624.99 RM
Cost per Unit	21.05 cents/kWH

Average Spinning Reserve During Peak Hour

Type	MW
GT	380
Hydro	407
Syncon	604
Thermal	183
Total	1,574

Time	Weather	Temperature
Afternoon	Hot	33
Morning	Cloudy	25

Gas Usage

Station	(mmcsfd)
GLGR	51
PGPS	22
TJGS	94
Total TNB	168
CBPS	49
KLPP	95
NPRI	141
PGLA	106
PLPS	69
SGB3	1
SGRI	35
SKSP	49
Total IPP	545
Total Gas	712
Total Gas Required	712

Alternate Fuel Usage

Station	(mmcsfd)
Total	0

Hourly System MW Generation

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
System Total	14542	13858	13423	13095	12794	12607	12889	12978	13548	15353	15999	16532	16380	16297	16506	17055	16948	16628	15760	16280	16576	16308	15699	15305

Prepared By: -Select Name-

Checked By: -Select Name-

Printed on: Monday, December 6, 2021 6:54:47 PM

(Ir. Shanmugam Thoppalan)
Head
Grid System Operator

Daily MW Generation on Thursday

Station	Unit	0000	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300																								
JMAH	U002	704	709	705	704	707	702	707	702	706	705	703	705	708	701	705	702	705	701	706	709	706	707	706	711	707	706	700	707	705	707	707	704	705	702	704	707	706	705	704	704	703	703	707	705	706			
JMHE	U001	925	930	920	869	868	846	847	853	851	849	849	851	848	852	921	966	979	979	980	978	979	981	982	980	977	980	980	983	980	982	979	980	978	976	978	981	983	982	981	983	979	975	983	978	979			
JMHE	U002	927	932	905	868	866	849	851	851	847	849	850	852	849	850	851	949	971	982	982	976	977	974	976	975	975	968	969	974	976	976	980	979	980	979	973	984	982	979	980	982	980	981	976	982	982	979		
JMJG	U002	673	673	675	675	674	673	673	674	674	672	673	671	673	674	673	676	672	673	672	673	672	674	671	672	672	672	678	672	670	675	672	672	676	674	670	673	672	674	673	672	674	675	672	674	675	672	670	671
JMJG	U003	665	666	667	667	667	666	665	668	668	669	666	666	664	667	665	666	662	666	666	667	664	668	667	666	665	663	666	664	666	667	671	667	667	667	668	667	663	666	668	665	662	667	668	666	666	667	661	668
JMJG	U004	934	931	929	870	872	852	852	851	852	851	852	854	854	852	852	854	851	884	939	978	977	975	975	976	977	976	977	976	977	980	980	981	977	978	978	976	977	978	980	977	980	975	977	978	977	978	978	977
JMJG	U005	889	890	885	870	868	843	848	849	851	851	852	849	851	850	852	834	855	894	891	888	890	892	892	894	888	891	892	887	887	888	890	892	890	890	889	892	891	890	892	891	892	892	892	892	890	891	891	890
PKLG	U004	279	276	272	271	268	267	264	270	268	200	203	208	211	243	277	281	275	276	272	271	273	273	273	273	276	273	266	269	250	249	253	252	253	259	257	252	253	255	263	273	277	275	272	271	274	272	266	
PKLG	U005	465	467	470	466	463	472	463	464	425	351	358	359	359	368	462	470	466	462	463	464	467	471	469	467	464	466	468	466	470	469	467	462	468	470	467	463	468	466	472	467	467	459	466	444	443	440	441	
PKLG	U006	449	449	449	446	447	450	449	450	450	449	448	448	449	448	445	446	446	446	446	445	446	440	440	448	446	450	449	452	452	455	453	453	450	449	446	446	446	447	449	446	445	446	446	446	444	444	449	453
TBIN	U001	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	75	197	279	275	304	
TBIN	U002	701	702	706	706	705	702	702	700	705	657	652	652	687	701	696	702	702	700	703	700	702	706	703	702	699	701	700	700	702	701	697	700	700	703	705	697	699	701	701	701	702	702	702	701	699	700	699	699
TBIN	U003	700	704	701	702	701	701	698	701	699	649	653	652	685	700	696	705	698	698	700	699	701	700	699	698	700	700	701	700	698	699	700	700	697	700	700	697	700	700	701	699	698	700	699	698	700	699	701	
Total ST-Coal		8311	8329	8284	8114	8106	8023	8019	8033	7996	7752	7760	7767	7834	7911	8022	8036	8032	8274	8390	8452	8464	8459	8453	8455	8449	8462	8460	8434	8438	8449	8445	8446	8439	8445	8451	8441	8415	8439	8453	8458	8463	8464	8456	8533	8618	8720	8699	8734
Total ST-Oil		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Total ST-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
CBPS	BLK2	220	219	217	226	220	223	215	218	217	225	219	226	226	230	219	222	223	358	365	358	362	365	362	362	362	362	362	362	361	361	362	362	364	360	353	346	366	361	361	357	360	355	353	354	352	358	357	
EMPP	BLK2	771	767	769	768	769	767	769	768	768	766	769	764	766	765	765	772	769	767	769	764	767	765	766	766	764	762	762	760	761	760	759	758	761	762	763	761	763	763	764	767	768	514	248	758	774	772		
GLGR	GT01	68	68	69	69	68	69	68	69	67	69	69	69	69	68	68	70	68	69	106	105	104	105	105	106	102	103	103	105	105	105	104	104	104	103	103	92	67	90	105	105	103	104	66	68	67	67		
GLGR	GT02	68	68	68	69	68	68	68	69	68	68	68	68	68	68	68	68	105	104	104	104	105	104	104	104	104	104	104	104	104	104	104	104	104	104	91	68	92	104	104	104	104	104	66	68	68	68		
GLGR	ST1C	71	71	71	71	71	71	71	71	71	71	71	71	71	71	71	71	92	94	94	93	93	93	93	93	93	93	93	93	93	93	93	93	93	90	71	81	94	93	93	93	93	71	71	71	70			
KLPP	GT13	119	119	119	119	119	123	118	120	119	121	119	124	124	123	115	122	121	120	126	135	134	133	130	130	130	127	128	131	127	134	127	131	127	128	122	117	113	116	113	109	113	712	110	109	108			
KLPP	GT14	117	120	116	115	116	122	116	116	122	116	122	124	123	116	122	122	118	122	155	156	155	155	157	157	157	157	157	157	156	157	157	157	156	157	158	158	121	158	157	157	156	156	156	156	117	117	117	
KLPP	GT15	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	30	140	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	145	140	140	140	140	140	140	140	0	0	
KLPP	ST17	134	134	134	134	134	136	134	134	134	135	134	136	136	133	134	134	135	144	143	149	212	212	212	212	211	212	212	211	211	211	210	211	211	211	210	201	209	208	208	208	208	208	208	199	135	132		
NPRI	BLK1	509	367	328	329	325	332	325	329	328	333	330	338	349	347	318	333	334	515	520	514	519	527	520	516	518	513	517	515	521	516	519	517	520	518	511	506	498	524	520	520	512	515	502	506	506	505	514	506
NPRI	BLK2	503	371	333	335	329	338	329	334	332	339	335	341	357	358	323	337	337	503	523	517	524	535	523	521	521	517	519	520	525	519	521	520	524	523	514	509	501	532	522	524	513	519	485	493	509	485	514	506
PCGP	PGRG	594	605	500	502	357	266	262	261	266	261	270	274	271	263	405	598	608	602	607	616	606	603	606	599	602	604	610	604	605	604	609	605	597	590	581	615	608	606	596	604	584	592	592	587	600	591		
PGLA	GT11	166	169	169	170	168	171	167	169	169	170	169	172	173	172	165	169	171	168	220	216	217	218	216	214	216	213	216	214	217	215	216	215	216	215	213	212	218	217	214	212	213	213	167	169	166			
PGLA	GT12	171	173	173	173	171	174	171	173	174	173	176	176	178	170	174	174	172	224	221	222	224	220	220	220	218	219	219	221	219	221	220	221	219	218	215	220	179	221	221	218	221	216	217	218	171	174	171	
PGLA	ST10	205	205	203	204	204	205	203	202	205	205	205	206	207	207	203	204	204	234	239	239	242	241	240	240	242	241	243	243	240	242	242	243	242	239	239	234	212	241	241	240	239	236	237	238	202	205	205	
PGPS	GT3A	69	70	70																																													

Daily MW Generation on Thursday

Station	Unit	0000	0100		0200		0300		0400		0500		0600		0700		0800		0900		1000		1100		1200		1300		1400		1500		1600		1700		1800		1900		2000		2100		2200		2300							
Total OCGT-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
BSIA	HY01	12	21	21	21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	22	22	22	11	11	11	12	12	21	21	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	12	12	12	12	12	12	12	12
BSIA	HY02	12	22	22	22	23	13	12	12	12	13	12	13	13	24	23	23	23	23	23	23	22	22	22	11	11	11	11	12	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	11	11	11	11	11	11	11	11		
BSIA	HY03	12	23	23	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	22	22	22	12	11	12	12	12	22	22	22	22	22	22	22	22	22	22	22	22	11	11	11	11	11	11	11	11	11				
CEND	HY01	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9				
CEND	HY02	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	8	9	9	9	8	9	8	9	8	9	8	9	8	9	9	9	9	9	9	9	9	9	9	9	9	9					
CEND	HY03	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9					
CEND	HY04	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7					
HTRG	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	63	64	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	63	63	-1	-1	-1	-1	-1	-1	-1				
HTRG	HY02	0	0	0	0	0	0	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1					
KNRG	HY01	34	25	24	25	24	25	23	24	24	25	25	25	25	35	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	34	22	23	23	23	22	22	22	22	23	22	22	23	22				
KNRG	HY02	36	24	23	23	23	24	23	23	23	24	23	24	24	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	36	24	25	25	25	24	24	24	24	24	24	24	24				
KNRG	HY03	35	22	21	21	21	22	21	21	21	21	22	21	22	22	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	20	22	22	22	22	21	21	21	21	21	21	21	21			
KNYR	HY01	63	66	65	64	64	65	62	62	64	67	65	71	84	87	62	66	63	71	97	94	96	96	96	74	89	92	97	96	97	96	95	95	96	95	85	84	82	81	67	68	65	65	62	62	64	60	63	63	63				
KNYR	HY02	56	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	95	95	95	95	95	60	59	59	96	60	95	95	95	95	95	95	58	59	56	-1	95	99	99	99	97	96	99	55	58	58	58				
KNYR	HY03	53	55	55	55	55	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	97	97	97	97	51	-1	-1	98	-1	97	97	97	97	97	97	-1	-1	-1	-1	97	97	97	97	96	97	-1	-1	-1	-1					
KNYR	HY04	58	60	60	63	62	62	60	60	61	62	62	61	76	76	60	62	59	69	76	80	99	98	98	74	77	99	84	85	85	84	97	98	98	97	87	87	84	100	99	99	60	64	58	57	59	57	72	60	60				
LPIA	HY01	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	23	26	26	26	26	26	26	26	26	26	26	26	26	25	25	25	25	25	25	25	25	25	25	25	25	25	25	25						
LPIA	HY02	21	20	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	21	22	22	21	21	21	21	21	21	21	21	21	21	21	21	22	22	22	22	21	21	21	21	21	21	21	21	21	21						
MNOR	HY01	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3					
PGAU	HY01	-1	-1	-1	-1	19	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	-1	-1	-1	-1	-1	-1	-1	-1	18	-1	-1	-1	-1	-1	-1	-1				
PGAU	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	20	20	21	21	21	20	20	20	20	20	20	20	20	20	21	21	13	0	0	0	0	0	0	0	0	0	0	0	0					
PGAU	HY04	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19	19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
SIHY	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	30	30	30	0	0	0	0	0	0	0	30	30	30	30	30	30	0	0	0	0	0	31	31	31	31	31	31	0	0			
SIHY	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	30	30	30	30	30	30	30	30	30	30	30	30	30	0	0	0	0	30	30	30	30	30	30	0	0	0						
SIHY	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
SYPS	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	0	0	0	0	17	17	17	17	17	17	0	0	0						
SYPS	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	0	0	0	0	17	17	17	17	17	17	0	0	0						
SYPS	HY04	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17	17	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
TMGR	HY01	33	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	80	80	80	35	35	35	35	35	80	80	80	80	80	80	31	30	28	32	32	80	80	62	59	61	30	0	0	0					
TMGR	HY02	0	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	85	84	85	33	33	33	34	33	84	84	84	84	84	33	31	-1	-1	85	84	85	64	61	63	32	31	33	32	32					
TMGR	HY03	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	80	80	80	33	-1	-1	-1	-1	80	80	80	80	80	30	-1	-1	-1	-1	80	80	60	57	59	29	-1	-1	-1	-1					
TMGR	HY04	42	42	41	41	41	42	40	41	40	41	40	44	55	56	39	41	44	50	83	75	83	81	81	55	71	76	82	82	82	80	81	81	81	69	67	65	83	77	81	43	47	39	40	41	41	54	42	42					
UJLI	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	97	95	95	-1	-1	-1	-1	-1	-1	93	93	93	95	94	89	88	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1						
UJLI	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1								
UPIA	HY01	5	5	5	6	5	5	5	5	6	5	5	5	5	5	5	5	5	5	5	5	6	5	5	5	5	5	5	5	5	5	5	6	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5					
UPIA	HY02	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5																							

Daily MW Generation on Thursday

Station	Unit	0000	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300	
KKLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
KRLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
MCLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	2	10	9	14	17	25	36	48	42	27	8	8
SPLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	15	23	30	23	24	27	35	51	38	52	50
SSLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	3	4	3	4	8	14	23	26	28	32	40
STLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	4	6	8	7	18	12	13	16	17	15	18
TBLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	1	4	18	13	30	24	30	30	30	22	21	20
Total LSS		0	0	0	0	0	0	0	0	0	0	0	0	0	7	62	95	134	175	234	266	329	346	320	305	278
PCUF	CUFG	29	26	28	27	28	28	29	29	28	29	27	27	28	28	28	26	25	24	23	23	22	22	21	22	20
PCUF	CUFK	14	12	14	13	13	14	14	14	14	15	14	14	14	15	16	13	13	14	14	15	14	13	12	13	14
Total Co-Gen		43	38	42	40	41	42	43	43	42	43	44	41	41	42	42	43	44	40	41	43	42	41	40	39	38
Total Gen		14565	14154	13830	13677	13475	13264	13128	12901	12825	12627	12607	12672	12822	13042	12992	13093	13519	14695	15231	15598	15909	16376	16452	16588	16286
TIE-EGAT		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TIE-HVDC		-29	-30	-30	-28	-28	-29	-29	-30	-30	-29	-29	-29	-30	-30	-30	-28	-28	-31	-31	-29	-30	-30	-29	-29	-28
TIE-PLTG		59	4	8	44	91	31	73	41	71	11	40	19	-27	7	55	-3	12	34	-82	-74	-49	-64	-39	-49	-55
Interconnection		30	-25	-21	17	63	2	44	12	42	-18	11	-10	-56	-23	25	-33	-18	5	-111	-104	-79	-94	-69	-80	-83
System Total		14542	14186	13858	13667	13423	13273	13095	12900	12794	12656	12607	12693	12889	13076	12978	13137	13548	14701	15353	15713	15999	16481	16532	16679	16380
SRev ST-Coal		311	293	338	409	413	435	444	426	452	568	573	574	504	481	436	442	429	321	237	175	163	168	174	172	178
SRev CCGT-Gas		1184	1525	1581	1566	1735	1778	1901	2141	2182	2145	2168	2119	2075	2080	2084	2013	1655	804	514	360	471	555	272	431	414
SRev LSS		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SRev ST-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SRev OCGT-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SRev Co-Gen		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Syncon		738	839	926	926	775	1027	1027	1093	1093	1093	1093	1093	1093	966	1153	1153	1153	1153	901	800	313	313	439	626	814
Hydro		342	243	247	243	376	205	215	215	212	204	210	198	159	199	169	161	165	141	90	231	204	420	423	433	539
S.Reserve Total		2575	2900	3092	3144	3299	3445	3587	3875	3939	4010	4044	3984	3831	3726	3842	3769	3402	2419	1994	1667	1638	1456	1182	1475	1757