

Availability at Daily Maximum Demand Hour

| | |
|---------------------|------------------|
| ST-Coal | 0 MW |
| ST-Gas | 0 MW |
| ST-Oil | 0 MW |
| Hydro | 2,212 MW |
| Distillate | 0 MW |
| Total TNB | 2,212 MW |
| Total IPP | 18,873 MW |
| Total Co-Gen | 0 MW |
| Total System | 24,367 MW |

Generation Mix

| Type | MWh | Percentage |
|-------------------------|----------------|-----------------|
| Hydro | 7,750 | 1.92 % |
| Gas | 49,740 | 12.30 % |
| Total TNB | 57,490 | 14.22 % |
| ST-Coal | 273,627 | 67.66 % |
| LSS | 5,734 | 1.42 % |
| Gas | 67,686 | 16.74 % |
| Total IPP | 347,047 | 85.82 % |
| Co-Gen | -267 | -0.07 % |
| Total Co-Gen | -267 | -0.07 % |
| Total Generation | 404,270 | 99.97 % |
| PLTG | -138 | -0.03 % |
| Interconnection | -138 | -0.03 % |
| Net Energy | 404,408 | 100.00 % |

Maximum Demand Record

| | |
|-----------------|-------------|
| Date: 5/11/2023 | 19,716 MW |
| Date: 5/11/2023 | 416,902 MWH |

Set On Bus, TNB, IPP And MD

| | |
|-------------------------------|---------------|
| Daily Maximum Demand Hour at: | 15:00:00 Hour |
| Total Set On Bus | 20,784 MW |
| TNB Generation | 2,940 MW |
| IPP Generation | 15,734 MW |
| Spinning Reserve | 2,132 MW |
| Maximum Demand | 18,648 MW |
| Net Energy | 404,408 MWH |
| Load Factor | 90.36 % |

Fuel Cost

| | |
|---------------|-------------------|
| Total Cost: | 103,377,299.67 RM |
| Cost per Unit | 25.53 cents/kWH |

Average Spinning Reserve During Peak Hour

| Type | MW |
|--------------|--------------|
| GT | 789 |
| Hydro | 260 |
| Syncon | 883 |
| Thermal | 193 |
| Total | 2,125 |

| Time | Weather | Temperature |
|-----------|---------|-------------|
| Afternoon | Hot | 37 |
| Morning | Sunny | 28 |

Gas Usage

| Station | (mmscfd) |
|---------------------------|------------|
| GLGR | 30 |
| TJGS | 162 |
| Total TNB | 192 |
| CBPS | 45 |
| EMPP | 176 |
| KLPP | 2 |
| NPRI | 73 |
| PCGP | 83 |
| PLPS | 71 |
| SPGP | 146 |
| Total IPP | 595 |
| Total Gas | 787 |
| Total Gas Required | 787 |

Alternate Fuel Usage

| Station | (mmscfd) |
|--------------|----------|
| Total | 0 |

Hourly System MW Generation

| | 00:00 | 01:00 | 02:00 | 03:00 | 04:00 | 05:00 | 06:00 | 07:00 | 08:00 | 09:00 | 10:00 | 11:00 | 12:00 | 13:00 | 14:00 | 15:00 | 16:00 | 17:00 | 18:00 | 19:00 | 20:00 | 21:00 | 22:00 | 23:00 |
|--------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| System Total | 17373 | 16533 | 15898 | 15384 | 14847 | 14612 | 14438 | 14423 | 14744 | 16324 | 17277 | 17797 | 17767 | 17567 | 18236 | 18648 | 18565 | 18282 | 17250 | 17042 | 18222 | 18234 | 17695 | 17448 |

Daily MW Generation on Thursday

| Station | Unit | 0000 | 0100 | 0200 | 0300 | 0400 | 0500 | 0600 | 0700 | 0800 | 0900 | 1000 | 1100 | 1200 | 1300 | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 |
|------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| CEND | HY04 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 |
| HTRG | HY01 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -1 | -1 | -1 | -1 | -1 | -1 |
| HTRG | HY02 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HTRG | HY03 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| HTRG | HY04 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 |
| KNRG | HY03 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 23 | 39 | 39 | 39 | 39 | 39 | 39 |
| KNYR | HY01 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 95 | 100 | 98 | 99 | 96 | 94 | -1 |
| KNYR | HY02 | 59 | 59 | 61 | 78 | 58 | 59 | 60 | 59 | 71 | 59 | 92 | 56 | 61 | 57 | 57 | 59 | 73 | 70 | 60 | 62 | 90 | 85 | 102 | 54 |
| KNYR | HY03 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 94 | 96 | 95 | 49 | 0 | |
| LPIA | HY01 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 12 | 12 | 12 | 12 | 12 | 12 | 12 | 11 | 11 | 11 | 8 |
| LPIA | HY02 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 10 | 8 | 8 | 8 | 8 |
| MNOR | HY01 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| PGAU | HY01 | -1 | -1 | -1 | -1 | -1 | -1 | 19 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 18 | -1 | -1 | -1 | -1 |
| PGAU | HY02 | -1 | -1 | -1 | -1 | 16 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PGAU | HY04 | -1 | -1 | 19 | -1 | -1 | -1 | 18 | -1 | -1 | -1 | 18 | -1 | -1 | -1 | 24 | -1 | -1 | -1 | 15 | -1 | -1 | -1 | -1 | -1 |
| SYPS | HY01 | 17 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SYPS | HY03 | 17 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 10 | 25 | 25 | 25 | 25 | 20 |
| TMGR | HY01 | -1 | -1 | -1 | -1 | 86 | 86 | 86 | 86 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | -1 | -1 | -1 | -1 | -1 | -1 |
| TMGR | HY02 | 0 | 0 | 0 | 0 | 0 | 0 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 36 | 37 | 36 | 37 | 33 | 32 | 33 | 30 | 36 | 37 | |
| TMGR | HY03 | 31 | 31 | 31 | 31 | 29 | 31 | 31 | 30 | 31 | 31 | 30 | 31 | 31 | 31 | 31 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 |
| TMGR | HY04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| UJLI | HY01 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | 87 | 80 | 92 | 86 | 88 |
| UJLI | HY02 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 | -1 |
| UPIA | HY01 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| UPIA | HY02 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 |
| Total Hydro | | 215 | 180 | 202 | 200 | 282 | 269 | 270 | 285 | 212 | 180 | 214 | 176 | 202 | 176 | 180 | 232 | 232 | 242 | 258 | 249 | 231 | 230 | 202 | 212 |
| Total Distillate | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| BDLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| BKLS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| BSLS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| CHLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| GBLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| GELS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| GNLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| JELS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| JSLs | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| KDLS | LSS3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| KKLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| KMLS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| KNLS | LSS3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| KRLS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| MALS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| MCLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| MNLS | LSS3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| PKLS | LSS3 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SPLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SSLS | LSS1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Daily MW Generation on Thursday

| Station | Unit | 0000 | 0100 | 0200 | 0300 | 0400 | 0500 | 0600 | 0700 | 0800 | 0900 | 1000 | 1100 | 1200 | 1300 | 1400 | 1500 | 1600 | 1700 | 1800 | 1900 | 2000 | 2100 | 2200 | 2300 | | | | | | | | | | | | | | | | | | | | | | | | | | |
|-----------------|------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|---|---|
| STLS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 2 | 4 | 6 | 11 | 14 | 18 | 20 | 16 | 23 | 13 | 17 | 15 | 19 | 20 | 17 | 15 | 5 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | | | | |
| TBLS | LSS2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 3 | 6 | 9 | 15 | 30 | 24 | 25 | 22 | 21 | 25 | 25 | 30 | 26 | 17 | 22 | 30 | 30 | 21 | 18 | 15 | 6 | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | |
| Total LSS | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 14 | 100 | 194 | 333 | 472 | 601 | 679 | 743 | 681 | 798 | 730 | 786 | 734 | 724 | 636 | 705 | 578 | 623 | 442 | 371 | 261 | 150 | 93 | 31 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | |
| ESTL | ESTL | 15 | 14 | 9 | 2 | 5 | 20 | 18 | 20 | 19 | 20 | 24 | 22 | 24 | 24 | 19 | 18 | 6 | 8 | 12 | 19 | 13 | 14 | 12 | 14 | 6 | 6 | 8 | 4 | 0 | 15 | 11 | 13 | 13 | 11 | 0 | 16 | 14 | 16 | 13 | 1 | 0 | 1 | 8 | 12 | 14 | 6 | 10 | 4 | | |
| KHTC | BLK1 | -22 | -21 | -19 | -19 | -19 | -20 | -18 | -19 | -18 | -15 | -16 | -14 | -19 | -14 | -16 | -21 | -24 | -26 | -31 | -32 | -31 | -35 | -36 | -41 | -38 | -36 | -40 | -41 | -47 | -39 | -40 | -39 | -39 | -41 | -39 | -36 | -33 | -33 | -30 | -26 | -26 | -27 | -24 | -24 | -23 | -20 | -19 | | | |
| PCUF | CUFG | 1 | 2 | 2 | 4 | 3 | 2 | 1 | 2 | 2 | 3 | 3 | 2 | 2 | 2 | 3 | 3 | 2 | 2 | 2 | 2 | 1 | 2 | 3 | 4 | 3 | 2 | 3 | 3 | 2 | 1 | 3 | 2 | 2 | 2 | 2 | 2 | 2 | 3 | 2 | 2 | 4 | 1 | 3 | 3 | 2 | 3 | | | | |
| PCUF | CUFK | 3 | 2 | 3 | 3 | 3 | 1 | 1 | 2 | 2 | 2 | 1 | 2 | 3 | 4 | 3 | 0 | 2 | 2 | 3 | 2 | 3 | 2 | 3 | 1 | 0 | 4 | 2 | 2 | 2 | 3 | 2 | 1 | 4 | 2 | 2 | 2 | 3 | 4 | 2 | 2 | 2 | 2 | 1 | 2 | 2 | 4 | 2 | | | |
| Total Co-Gen | | -3 | -3 | -5 | -10 | -8 | 4 | 0 | 6 | 4 | 7 | 13 | 10 | 16 | 11 | 10 | 4 | -10 | -11 | -9 | -8 | -14 | -15 | -19 | -16 | -30 | -29 | -22 | -31 | -37 | -27 | -22 | -23 | -24 | -21 | -37 | -19 | -18 | -12 | -14 | -24 | -22 | -21 | -13 | -10 | -5 | -12 | -4 | -10 | | |
| Total Gen | | 17401 | 16912 | 16555 | 16170 | 15929 | 15615 | 15419 | 15067 | 14836 | 14702 | 14623 | 14437 | 14435 | 14467 | 14433 | 14323 | 14713 | 15598 | 16308 | 16754 | 17277 | 17575 | 17790 | 17939 | 17775 | 17590 | 17587 | 17860 | 18246 | 18548 | 18652 | 18546 | 18551 | 18518 | 18270 | 17710 | 17255 | 16897 | 17009 | 17765 | 18213 | 18209 | 18200 | 17850 | 17678 | 17497 | 17402 | 17155 | | |
| TIE-EGAT | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | |
| TIE-HVDC | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| TIE-PLTG | | 28 | 33 | 22 | -2 | 31 | 13 | 35 | 36 | -11 | 20 | 11 | 0 | -3 | 1 | 10 | -17 | -31 | -41 | -16 | -16 | 0 | 32 | -7 | 22 | 8 | 5 | 20 | -14 | 10 | -33 | 4 | -60 | -14 | -21 | -12 | -14 | 5 | -4 | -33 | -52 | -9 | -17 | -34 | -32 | -17 | -43 | -46 | -23 | | |
| Interconnection | | 28 | 33 | 22 | -2 | 31 | 13 | 35 | 36 | -11 | 20 | 11 | 0 | -3 | 1 | 10 | -17 | -31 | -41 | -16 | -16 | 0 | 32 | -7 | 22 | 8 | 5 | 20 | -14 | 10 | -33 | 4 | -60 | -14 | -21 | -12 | -14 | 5 | -4 | -33 | -52 | -9 | -17 | -34 | -32 | -17 | -43 | -46 | -23 | | |
| System Total | | 17373 | 16879 | 16533 | 16172 | 15898 | 15602 | 15384 | 15031 | 14847 | 14682 | 14612 | 14437 | 14438 | 14466 | 14423 | 14340 | 14744 | 15639 | 16324 | 16770 | 17277 | 17543 | 17797 | 17917 | 17767 | 17585 | 17567 | 17874 | 18236 | 18581 | 18648 | 18606 | 18565 | 18539 | 18282 | 17724 | 17250 | 16901 | 17042 | 17817 | 18222 | 18226 | 18234 | 17882 | 17695 | 17540 | 17448 | 17178 | | |
| SRev ST-Coal | | 194 | 310 | 316 | 319 | 354 | 308 | 300 | 509 | 558 | 540 | 563 | 638 | 670 | 641 | 752 | 918 | 845 | 324 | 204 | 197 | 227 | 178 | 182 | 214 | 176 | 216 | 187 | 196 | 200 | 161 | 190 | 197 | 200 | 175 | 225 | 170 | 195 | 344 | 328 | 181 | 183 | 190 | 174 | 199 | 197 | 181 | 201 | 196 | | |
| SRev CCGT-Gas | | 614 | 542 | 658 | 1046 | 1110 | 1491 | 1691 | 1818 | 1787 | 1856 | 2018 | 2185 | 2139 | 2253 | 2261 | 2193 | 2125 | 2009 | 1639 | 1405 | 971 | 811 | 661 | 443 | 818 | 868 | 1166 | 993 | 632 | 714 | 759 | 680 | 903 | 889 | 1059 | 1286 | 1451 | 1498 | 1368 | 662 | 371 | 345 | 427 | 660 | 804 | 543 | 516 | 633 | | |
| SRev LSS | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| SRev ST-Gas | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SRev OCGT-Gas | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SRev Co-Gen | | 44 | 42 | 38 | 38 | 38 | 38 | 40 | 36 | 38 | 36 | 30 | 32 | 28 | 38 | 28 | 32 | 42 | 48 | 52 | 62 | 64 | 62 | 70 | 72 | 82 | 76 | 72 | 80 | 82 | 94 | 78 | 80 | 78 | 78 | 82 | 78 | 72 | 66 | 66 | 60 | 52 | 52 | 54 | 48 | 48 | 46 | 40 | 38 | | |
| Syncon | | 1142 | 1142 | 991 | 1142 | 903 | 1054 | 1054 | 903 | 991 | 1142 | 1142 | 1142 | 991 | 1142 | 1142 | 1054 | 903 | 752 | 903 | 991 | 928 | 1079 | 928 | 953 | 953 | 953 | 1230 | 1079 | 955 | 854 | 942 | 766 | 766 | 428 | 953 | 903 | 1142 | 1142 | 802 | 802 | 953 | 953 | 953 | 802 | 953 | 1180 | 1268 | | | |
| Hydro | | 182 | 167 | 296 | 147 | 304 | 166 | 165 | 301 | 286 | 167 | 133 | 171 | 296 | 171 | 171 | 167 | 203 | 204 | 345 | 265 | 186 | 267 | 117 | 296 | 223 | 164 | 291 | 112 | 292 | 209 | 251 | 213 | 382 | 268 | 547 | 231 | 336 | 143 | 109 | 332 | 275 | 148 | 99 | 194 | 380 | 192 | 200 | 141 | | |
| S.Reserve Total | | 2263 | 2290 | 2386 | 2779 | 2796 | 3144 | 3337 | 3654 | 3660 | 3741 | 3886 | 4168 | 4124 | 4245 | 4354 | 4452 | 4269 | 3488 | 2992 | 2832 | 2439 | 2246 | 2109 | 1953 | 2252 | 2277 | 2669 | 2611 | 2285 | 2133 | 2132 | 2112 | 2329 | 2176 | 2341 | 2805 | 3044 | 3280 | 3100 | 2037 | 1683 | 1688 | 1707 | 2054 | 2231 | 2002 | 2224 | 2363 | | |