

Availability at Daily Maximum Demand Hour

ST-Coal	0 MW
ST-Gas	0 MW
ST-Oil	0 MW
Hydro	2,325 MW
Distillate	0 MW
Total TNB	2,325 MW
Total IPP	15,744 MW
Total Co-Gen	0 MW
Total System	21,351 MW

Maximum Demand Record

Date: 5/11/2023	19,716 MW
Date: 5/11/2023	416,902 MWH

Gas Usage

Station	(mmscfd)	Station	(mmscfd)
GLGR	51	Total	0
TJGS	177		
Total TNB	228		
CBPS	47		
EMPP	188		
KLPP	52		
NPRI	142		
PCGP	84		
PLPS	3		
SGRI	49		
SKSP	35		
SPGP	127		
Total IPP	727		
Total Gas	955		
Total Gas Required	955		

Alternate Fuel Usage

Set On Bus, TNB, IPP And MD

Daily Maximum Demand Hour at:	16:30:00 Hour
Total Set On Bus	19,167 MW
TNB Generation	3,580 MW
IPP Generation	14,188 MW
Spinning Reserve	1,443 MW
Maximum Demand	17,739 MW
Net Energy	374,039 MWH
Load Factor	87.86 %

Generation Mix

Type	MWh	Percentage
Hydro	18,867	5.04 %
Gas	52,056	13.92 %
Total TNB	70,923	18.96 %
ST-Coal	208,482	55.74 %
LSS	5,512	1.47 %
Gas	89,341	23.89 %
Total IPP	303,335	81.10 %
Co-Gen	-520	-0.14 %
Total Co-Gen	-520	-0.14 %
Total Generation	373,738	99.92 %
PLTG	-307	-0.08 %
EGAT	6	0.00 %
Interconnection	-301	-0.08 %
Net Energy	374,039	100.00 %

Fuel Cost

Average Spinning Reserve During Peak Hour

Type	MW
GT	703
Hydro	378
Syncon	599
Thermal	162
Total	1,842

Time Weather Temperature

Hourly System MW Generation

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
System Total	14896	14225	13684	13179	12769	12665	12881	13007	13614	15490	16324	16816	16871	16636	17312	17604	17686	17405	16283	16281	17380	17386	16755	16344

Daily MW Generation on Monday

Station	Unit	0000	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300
BSIA	HY01	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22	22
BSIA	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BSIA	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CEND	HY01	5	6	6	6	6	6	6	7	7	7	8	8	8	7	7	8	8	7	8	8	7	7	8	8
CEND	HY02	5	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
CEND	HY03	7	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
CEND	HY04	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
HTRG	HY01	68	68	68	68	68	68	68	68	68	68	68	68	68	68	123	123	100	100	99	99	99	99	99	99
HTRG	HY02	68	68	68	68	68	68	68	68	68	68	68	68	68	68	121	121	99	99	99	99	99	99	99	99
HTRG	HY03	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7
HTRG	HY04	3	3	3	3	4	3	3	4	4	3	4	4	4	3	4	3	3	3	3	3	3	3	3	3
KNRG	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
KNRG	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
KNRG	HY03	22	22	22	22	22	22	22	22	22	22	22	22	22	39	39	39	39	37	37	37	37	37	37	37
KNYR	HY01	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99
KNYR	HY02	100	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99	99
KNYR	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
LPIA	HY01	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	12	13	15	15	15
LPIA	HY02	9	9	9	9	9	9	9	9	9	9	9	9	9	9	10	10	10	10	10	13	15	15	15	15
MNOR	HY01	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3
PGAU	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1
PGAU	HY02	-1	-1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PGAU	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SIHY	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SIHY	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SIHY	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SYPS	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SYPS	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SYPS	HY04	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TMGR	HY01	34	33	33	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1
TMGR	HY02	89	46	74	74	46	46	46	73	45	46	80	63	88	70	46	86	90	90	89	90	89	90	89	90
TMGR	HY03	0	0	0	32	32	32	2	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TMGR	HY04	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1
UJLI	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1
UJLI	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1
UPIA	HY02	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6
Total Hydro		559	508	537	535	509	508	478	479	504	472	475	511	517	609	501	475	518	523	580	580	557	589	564	698
Total Distillate		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BDLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BKLS	LSS2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BSLS	LSS2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CHLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
GBLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
GELS	LSS2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
GNLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
JELS	LSS2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
JLSL	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

