

Daily System Generation Summary on Sunday

Sunday, February 24, 2019

Availability at Daily Maximum Demand Hour

ST-Coal	0 MW
ST-Gas	0 MW
ST-Oil	0 MW
Hydro	2,166 MW
Distillate	0 MW
Total TNB	2,166 MW
Total IPP	16,844 MW
Total Co-Gen	55 MW
Total System	22,144 MW

Generation Mix

Type	MWh	Percentage
Hydro	6,712	2.02 %
Gas	34,381	10.36 %
Total TNB	41,093	12.38 %
ST-Coal	214,492	64.62 %
LSS	1,907	0.57 %
Gas	72,640	21.89 %
Total IPP	289,039	87.08 %
Co-Gen	789	0.24 %
Total Co-Gen	789	0.24 %
Total Generation	330,921	99.70 %
PLTG	-260	-0.08 %
HVDC	-728	-0.22 %
Interconnection	-988	-0.30 %
Net Energy	331,909	100.00 %

Maximum Demand Record

Date: 8/15/2018	18,338 MW
Date: 8/15/2018	388,524 MWH

Set On Bus, TNB, IPP And MD

Daily Maximum Demand Hour at:	21:00:00 Hour
Total Set On Bus	17,009 MW
TNB Generation	2,164 MW
IPP Generation	13,342 MW
Spinning Reserve	1,470 MW
Maximum Demand	15,586 MW
Net Energy	331,909 MWH
Load Factor	88.73 %

Fuel Cost

Total Cost:	66,745,929.92 RM
Cost per Unit	20.81 cents/kWH

Average Spinning Reserve During Peak Hour

Type	MW
GT	585
Hydro	337
Syncon	867
Thermal	136
Total	1,925

Time Weather Temperature

Afternoon	Hot	34
Morning	Sunny	28

Gas Usage

Station	(mmscfd)
GLGR	56
TJGS	190
Total TNB	246
CBPS	50
KLPP	56
NPRI	145
PGLA	51
PLPS	53
SGRI	36
SKSP	4
YPKA	32
Total IPP	427
Total Gas	673
Total Gas Required	673

Alternate Fuel Usage

Station	(mmscfd)
Total	0

Hourly System MW Generation

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
System Total	15051	14353	13897	13349	13172	12924	12683	12446	11775	12357	13021	13506	13606	13659	14072	14213	14396	14304	13786	13834	15464	15586	15441	15258

Prepared By: -Select Name-

Checked By: -Select Name-

Printed on: Friday, March 01, 2019 10:02:39 AM

(Ir. Shanmugam Thoppalan)
Pengurus Besar Kanan
Jabatan Sistem Operasi

Daily MW Generation on Sunday

[illegible]

Daily MW Generation on Sunday

Station	Unit	0000	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300																													
Total CCGT-Gas		5568	5224	5124	5030	4864	4642	4474	4329	4250	4055	3976	3797	3876	3972	3801	3293	3158	3105	3280	3369	3628	3965	4159	4166	4097	3843	3855	4293	4322	4664	4443	4426	4685	4682	4691	4223	4006	4036	4199	5071	5683	5699	5771	5786	5826	5773	5661	5214					
Total OCGT-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
BSIA	HY02	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11	11				
CEND	HY01	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9			
CEND	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
CEND	HY03	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9			
HTRG	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
HTRG	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
KNRG	HY02	26	26	26	26	26	26	25	25	25	25	25	25	25	26	25	26	25	26	25	26	25	26	25	26	25	26	25	26	25	26	25	26	25	25	25	25	25	25	26	25	26	26	26	26	25	26	25	26	25	26			
KNYR	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	58	0	0	100	101	101	102	98	99	95	95	96	100	99	100	0	0	0	0	0	0	0	0	0	0	0	
KNYR	HY03	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
KNYR	HY04	60	60	60	62	62	60	58	57	60	60	59	54	60	61	59	54	57	54	59	55	59	60	60	59	59	57	58	61	59	62	96	100	102	102	102	99	100	96	96	97	101	100	101	60	61	60	60	60	60	60	60		
LPIA	HY01	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9	9			
LPIA	HY02	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10		
MNOR	HY01	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2			
PGAU	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
PGAU	HY02	-1	-1	-1	-1	-1	18	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
PGAU	HY04	21	21	21	21	22	22	22	21	21	21	21	22	21	21	22	22	22	22	22	21	22	22	21	21	22	22	22	22	22	22	22	22	22	22	22	21	23	22	22	21	23	22	22	21	21	21	21	21	22	22			
SIHY	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SYPS	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
TMGR	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
TMGR	HY02	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35	35			
TMGR	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
TMGR	HY04	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
UJLI	HY01	-1	-1	-1	-1	93	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
UJLI	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
UPIA	HY01	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3		
UPIA	HY02	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4		
Total Hydro		191	191	191	193	288	211	189	187	190	190	189	180	190	192	189	179	186	179	216	184	191	192	191	191	191	187	214	195	446	195	246	435	439	439	441	430	430	416	411	432	438	433	505	385	325	256	272	279					
Total Distillate		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
BDLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	4	8	13	17	20	22	24	25	27	29	15	22	27	27	25	22	20	17	12	8	4	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CHLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	9	14	21	17	31	35	39	41	37	33	29	44	39	38	21	16	21	26	20	14	7	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
GNLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	9	15	23	21	35	40	43	46	49	50	50	40	39	46	45	40	35	30	22	16	8	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
KKLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	7	13	16	24	35	41	40	44	45	46	45	46	45	43	40	37	32	26	19	11	5	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
SPLS	LSS1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	8	19	29	37	45	50	52	54	53	57	57	51	57	53	49	43	39	31	21	12	4	1																

Daily MW Generation on Sunday

[illegible]