

Availability at Daily Maximum Demand Hour

ST-Coal	0 MW
ST-Gas	0 MW
ST-Oil	0 MW
Hydro	2,375 MW
Distillate	0 MW
Total TNB	2,375 MW
Total IPP	17,730 MW
Total Co-Gen	0 MW
Total System	22,580 MW

Generation Mix

Type	MWh	Percentage
Hydro	11,077	2.99 %
Gas	29,643	7.99 %
Total TNB	40,720	10.98 %
ST-Coal	242,887	65.49 %
LSS	2,715	0.73 %
Gas	83,720	22.57 %
Total IPP	329,322	88.79 %
Co-Gen	200	0.05 %
Total Co-Gen	200	0.05 %
Total Generation	370,242	99.82 %
PLTG	-71	-0.02 %
HVDC	-583	-0.16 %
Interconnection	-654	-0.18 %
Net Energy	370,896	100.00 %

Maximum Demand Record

Date: 4/18/2019	18,566 MW
Date: 4/18/2019	391,845 MWH

Set On Bus, TNB, IPP And MD

Daily Maximum Demand Hour at:	16:00:00 Hour
Total Set On Bus	19,171 MW
TNB Generation	2,447 MW
IPP Generation	14,955 MW
Spinning Reserve	1,763 MW
Maximum Demand	17,465 MW
Net Energy	370,896 MWH
Load Factor	88.49 %

Fuel Cost

Total Cost:	59,611,977.86 RM
Cost per Unit	16.09 cents/kWH

Average Spinning Reserve During Peak Hour

Type	MW
GT	578
Hydro	293
Syncon	965
Thermal	166
Total	2,002

Time	Weather	Temperature
Afternoon	Hot	33
Morning	Sunny	27

Gas Usage

Station	(mmscfd)
GLGR	47
TJGS	169
Total TNB	216
CBPS	48
KLPP	87
NPRI	139
PGLA	101
PLPS	81
SGRI	56
YPKA	0
Total IPP	512
Total Gas	727
Total Gas Required	727

Alternate Fuel Usage

Station	(mmscfd)
Total	0

Hourly System MW Generation

	00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
System Total	15211	14466	13910	13495	13114	12911	13224	13285	13463	15218	15982	16569	16569	16374	16991	17334	17465	17162	16005	15758	16871	16866	16383	16108

Daily MW Generation on Wednesday

Station	Unit	0000	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300																									
JMAH	U002	690	696	694	695	692	693	695	694	694	695	699	693	694	695	694	695	696	696	690	693	693	693	692	695	697	693	693	694	686	694	692	695	693	694	695	696													
JMHE	U001	978	982	978	886	828	829	831	827	834	830	831	830	827	831	830	829	832	829	961	979	980	979	977	980	978	979	977	980	978	981	980	980	980	979	980	982	979	982											
JMHE	U002	979	980	827	833	830	829	832	829	834	830	831	830	827	831	830	829	832	829	982	978	982	979	978	979	978	978	981	982	980	980	980	979	980	981	980	979	980												
JMJG	U001	667	673	672	672	676	672	671	573	520	497	496	496	543	596	601	593	628	676	682	673	670	671	672	671	672	674	668	663	666	671	670	671	671	672	672	677	673	672	671	672	668	669	673	664	668	673	662	682	
JMJG	U003	667	667	671	668	671	668	668	577	519	495	497	497	515	593	596	595	612	677	673	667	668	667	672	663	667	667	667	669	667	668	667	669	667	667	667	666	667	668	663	668	665	669	662	673	662	664	668	667	
JMJG	U004	900	898	862	834	834	835	833	834	836	835	834	835	834	836	834	834	837	834	899	897	897	898	898	898	899	898	899	900	899	899	897	899	899	898	899	900	899	898	897	900	900	899	900	901	901	898	898		
JMJG	U005	978	979	979	906	826	831	828	829	833	832	832	829	830	833	831	830	832	832	930	980	982	980	980	977	977	977	982	979	979	980	979	978	979	978	978	977	979	977	980	980	976	979	977	978	979	979	977	977	
PKLG	U003	281	290	280	280	281	276	282	278	282	282	218	250	254	274	279	283	283	286	278	282	284	287	291	284	282	282	281	280	269	276	276	278	286	286	281	280	277	285	279	280	275	282	279	275	280	282	282		
PKLG	U004	279	276	279	266	207	250	286	280	283	279	215	251	284	285	282	283	285	281	282	277	281	277	277	281	276	276	280	278	282	280	281	279	284	280	278	281	281	281	281	274	278	278	281	281	279	282			
PKLG	U005	468	468	468	467	468	468	468	468	422	327	271	268	346	432	466	466	468	468	464	466	466	466	468	470	464	466	466	468	464	466	467	467	463	467	467	469	466	464	468	471	461	468	472	466	465	466	469		
PKLG	U006	449	450	448	446	448	446	449	453	449	448	447	447	446	446	449	446	447	446	449	445	453	451	448	448	448	451	452	446	446	451	446	449	445	449	448	448	448	449	448	449	448	450	449	450	450	451	447	448	
TBIN	U001	688	690	689	690	690	690	694	691	692	690	691	690	689	689	690	690	690	690	692	691	691	690	690	689	690	687	690	689	686	686	688	687	687	688	687	689	687	687	685	688	689	687	687	688	690	687			
TBIN	U002	692	693	693	692	691	691	693	689	688	692	692	691	688	691	691	691	689	691	692	696	691	690	691	690	690	691	690	690	691	691	698	691	691	695	690	691	691	691	691	690	692	689	689	692	691	691	691	692	693
TBIN	U003	690	692	691	691	693	693	693	691	690	692	691	690	691	693	692	693	691	690	691	688	694	689	692	689	694	690	689	690	690	691	694	689	692	694	688	690	693	690	690	691	690	690	693	691	692	692	690	690	
TBIN	U004	983	983	983	983	832	832	833	833	833	833	833	832	834	832	834	832	834	904	984	981	980	982	983	983	982	983	983	981	981	984	981	982	982	981	983	984	983	981	981	981	981	981	983	985	982	982			
Total ST-Coal		10389	10417	10214	10009	9667	9703	9756	9546	9409	9257	9070	9132	9306	9556	9601	9588	9655	9752	10279	10391	10412	10400	10403	10399	10407	10392	10392	10394	10383	10398	10386	10394	10392	10402	10396	10397	10407	10395	10393	10399	10373	10381	10397	10401	10388	10405	10386	10415	
Total ST-Oil		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Total ST-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
CBPS	BLK2	349	297	216	216	217	214	213	215	213	217	224	220	213	226	212	205	220	359	352	350	354	358	357	361	352	356	351	359	355	355	357	357	354	355	360	352	277	222	219	352	360	362	362	362	361	357	361	362	
GLGR	GT01	67	68	69	69	68	68	69	69	69	68	68	67	69	67	68	67	66	66	66	67	68	67	66	67	107	86	87	86	88	79	67	67	69	67	82	87	85	84	85	85	85	86	76	66	68	67			
GLGR	ST02	69	68	68	68	68	68	68	68	68	69	68	68	68	68	69	68	68	68	68	68	67	70	68	68	68	67	103	84	84	84	84	78	68	68	68	68	83	86	86	85	85	86	76	68	68				
GLGR	ST1C	70	70	70	70	70	70	70	71	70	71	70	70	70	70	70	69	70	70	69	70	70	71	71	68	71	89	80	80	80	80	79	70	71	70	75	80	80	80	80	80	80	80	78	70	70				
KLPP	GT13	67	71	71	70	70	70	70	71	70	71	70	71	69	65	70	71	106	106	109	115	121	115	112	111	115	119	120	114	130	125	131	138	132	116	114	117	117	113	114	131	136	120	115	119	118	115			
KLPP	GT14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19	98	121	115	125	131	124	124	124	123	127	130	122	141	133	142	157	142	126	123	125	125	124	124	141	145	134	123	128	128	126			
KLPP	GT15	78	78	81	81	82	82	78	78	81	81	81	86	80	82	81	77	81	132	130	119	118	125	129	125	125	125	123	127	130	123	141	136	144	151	144	127	123	127	127	123	124	141	141	133	125	125	128	125	
KLPP	ST17	93	84	89	84	89	89	88	88	84	84	89	89	89	89	88	81	92	103	177	187	186	191	194	191	190	190	190	190	194	190	198	198	203	198	190	190	186	186	190	190	198	198	194	194	194	194	194		
NPRI	BLK1	497	451	467	328	373	330	330	331	325	364	413	433	441	365	320	310	385	460	431	429	490	508	506	506	499	498	508	511	511	505	511	509	509	511	506	443	335	333	325	508	508	508	508	508	509	505	509		
NPRI	BLK2	497	500	506	506	508	322	317	320	320	326	323	317	327	315	301	326	476	500	498	508	505	507	499	498	508	511	511	506	511	508	509	511	505	507	440	308	301	511	510	510	511	511	511	511	511	508	513		
PCGP	PGRG	575	579	590	592	596	590	413	393	402	399	402	487	502	486	372	403	600	586	583	596	598	599	596	585	582	598	600	603	594	601	600	600	600	600	600	600	605	594	602	601	601	601	601	601	601	597	602		
PGLA	GT11	164	161	164	164	162	163	163	163	164	166	165	165	161	164	161	156	163	201	162	158	194	165	194	162	159	160	162	170	188	163	208	195	208	208	198	164	163	165	164	165	161	209	200	189	191	205	197	189	
PGLA	GT12	187	183	185	185	184	185	184	185	185	188	187	189	183	188	184	177	187	223	184	182	217	188	216	184	183	181	184	192	211	184	232	218	230	231	220	186	183	187	185	186	183	232	221	212	212	228	219	211	
PGLA	ST10	208	205	205	203	212	204	202	204	202	204	205	205	206	206	202	200</																																	

Daily MW Generation on Wednesday

Station	Unit	0000	0100	0200	0300	0400	0500	0600	0700	0800	0900	1000	1100	1200	1300	1400	1500	1600	1700	1800	1900	2000	2100	2200	2300																											
Total CCGT-Gas		4539	4056	4029	3933	4010	3760	3509	3477	3457	3543	3603	3625	3678	3658	3531	3331	3568	4483	4592	4843	5136	5425	5604	5450	5390	5213	5103	5165	5544	5525	5606	5643	5723	5701	5533	5151	4686	4461	4507	5395	5603	5658	5614	5547	5303	5345	5284	5201			
Total OCGT-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
BSIA	HY01	22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
BSIA	HY02	20	12	12	12	12	12	12	12	12	12	21	12	11	11	12	11	11	12	12	21	22	21	21	22	22	22	21	21	21	21	21	21	21	11	11	11	11	21	12	12	13	13	13	22	22	22	22	22	22		
BSIA	HY03	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
CEND	HY01	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8		
CEND	HY02	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8	8		
CEND	HY04	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7	7		
HTRG	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1		
HTRG	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1			
KNRG	HY02	36	36	36	22	22	22	22	22	22	22	22	36	22	22	21	22	22	21	21	22	22	36	36	36	36	36	36	36	35	35	35	35	35	35	24	24	24	35	23	23	24	23	24	23	24	23	24	23	23	23	
KNRG	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
KNYR	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	57	98	98	99	98	98	98	100	99	99	98	98	97	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1
KNYR	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
KNYR	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
KNYR	HY04	57	53	53	53	60	58	57	57	56	57	59	58	60	56	54	58	58	56	56	57	58	58	59	57	57	58	99	100	99	100	100	100	100	99	99	99	60	59	61	59	73	60	60	61	59	59	59	59	59	59	
LPIA	HY01	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	18	18	18	18	18	18		
MNOR	HY01	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	4	4	4	4	4	6	6	4	4	4	4	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	6	4	4	
PGAU	HY01	-1	-1	-1	-1	-1	-1	-1	-1	16	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	21	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	
PGAU	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1		
PGAU	HY03	0	0	0	0	0	0	0	0	0	0	0	0	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1		
SIHY	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SIHY	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SYPS	HY01	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SYPS	HY02	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SYPS	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SYPS	HY04	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
TMGR	HY01	30	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	52	52	51	51	31	31	32	52	52	52	52	51	83	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82	82
TMGR	HY02	30	31	33	33	33	33	32	32	33	33	33	80	35	33	29	35	35	33	32	35	35	35	35	33	32	35	36	36	56	57	57	55	54	79	79	79	79	79	63	64	63	63	64	64	0	0	0	0	0	0	
TMGR	HY03	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	82	
TMGR	HY04	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
UJLI	HY01	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1		
UJLI	HY02	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1	-1		
UPIA	HY01	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	4	
UPIA	HY02	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	
Total Hydro		262	175	177	163	170	168	166	166	183	167	169	169	238	171	164	158	170	192	165	164	170	171	247	407	344	319	485	598	599	900	966	965	985	1065	1020	904	815	752	795	701											

Daily MW Generation on Wednesday

Station	Unit	0000	0100		0200		0300		0400		0500		0600		0700		0800		0900		1000		1100		1200		1300		1400		1500		1600		1700		1800		1900		2000		2100		2200		2300		
PCUF	CUFG	4	2	3	5	4	4	5	3	3	4	5	5	3	2	4	3	4	4	4	4	3	4	3	4	4	4	4	4	3	4	2	4	3	4	3	5	3	3	4	4	3	4	4	4				
PCUF	CUFK	4	3	5	6	4	5	5	5	5	5	6	6	4	3	4	5	6	4	5	5	5	6	3	5	4	4	5	4	4	4	3	7	4	5	4	5	5	5	5	4	6	6	4	4	5	5	5	4
Total Co-Gen		8	5	8	11	8	9	10	8	8	9	11	11	7	5	8	8	10	8	9	9	8	10	6	9	8	8	9	8	8	8	6	11	6	9	7	9	8	10	8	7	10	10	7	8	8	9	9	8
Total Gen		15198	14653	14428	14116	13855	13640	13441	13197	13057	12976	12853	12937	13229	13390	13304	13085	13423	14494	15172	15589	15949	16293	16558	16615	16517	16286	16297	16501	16920	17207	17294	17315	17408	17397	17189	16622	16030	15676	15725	16511	16788	16822	16809	16650	16361	16363	16110	15929
TIE-EGAT		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
TIE-HVDC		-29	-29	-29	-29	-29	-29	-29	-29	-29	-29	-29	-29	-29	-28	-28	-29	-29	-29	-29	-29	-29	-29	-29	-30	-30	-30	-30	-30	-30	-29	-29	29	29	29	29	-29	-29	-29	-29	-29	-29	-30	-30	-30	-30			
TIE-PLTG		24	17	-2	-16	-18	-11	-18	18	-22	-20	-22	-45	42	79	54	45	-4	19	-10	-19	3	9	25	-24	-15	8	-36	-47	-30	8	0	-18	-17	-41	8	-12	7	-21	7	-29	-43	0	-17	1	14	-18	39	6
Interconnection		-6	-12	-31	-45	-48	-40	-47	-11	-50	-49	-51	-74	12	50	26	17	-33	-10	-39	-48	-26	-21	-4	-53	-45	-22	-66	-77	-60	-22	-29	-47	-46	-12	38	17	36	-50	-22	-58	-72	-29	-46	-28	-15	-48	9	-24
System Total		15211	14672	14466	14168	13910	13687	13495	13215	13114	13032	12911	13018	13224	13347	13285	13075	13463	14511	15218	15644	15982	16321	16569	16675	16569	16319	16374	16589	16991	17240	17334	17373	17465	17420	17162	16616	16005	15737	15758	16580	16871	16862	16866	16685	16383	16418	16108	15960
SRev ST-Coal		166	138	141	-158	134	98	129	247	273	304	358	361	337	296	259	263	241	153	276	164	143	155	152	156	148	163	163	161	172	157	169	161	163	153	159	158	148	160	162	156	182	174	158	154	167	150	169	140
SRev OCGT-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SRev CCGT-Gas		1211	1629	1526	1637	1560	1810	2046	1978	1998	1912	1852	1830	1777	1797	1924	2124	1887	1022	963	1052	896	607	473	627	687	864	974	932	573	592	392	474	394	296	464	846	1311	1536	1590	773	642	447	415	482	509	467	528	611
SRev ST-Gas		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SRev LSS		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SRev Co-Gen		62	65	62	59	62	61	60	62	62	61	59	59	63	65	62	62	60	62	61	61	62	60	64	61	62	62	61	62	62	62	64	59	64	61	63	61	62	60	62	63	60	60	63	62	62	61	61	62
Syncon		1029	1116	1116	1116	1116	1116	1116	1116	965	1116	1116	1116	1116	1267	1267	1267	1267	1116	1267	1267	1267	1267	1180	1180	1180	1029	1079	1079	1079	928	741	741	741	554	705	741	1079	1079	1079	993	806	806	655	993	993	993	993	1180
Hydro		185	137	135	149	142	144	146	146	280	145	143	143	74	140	147	153	141	270	146	147	141	140	151	314	302	403	214	187	186	387	421	422	402	509	403	383	134	97	54	234	329	309	442	201	233	204	177	110
S.Reserve Total		2653	3085	2980	2803	3014	3229	3497	3549	3578	3538	3528	3509	3367	3565	3659	3869	3596	2623	2713	2691	2509	2229	2020	2338	2379	2521	2491	2421	2072	2126	1787	1857	1764	1573	1794	2189	2734	2932	2947	2219	2019	1796	1733	1892	1964	1875	1928	2103