


DATA PRESTASI LOJI PENJANAAN TENAGA ELEKTRIK DI SABAH


1. Jumlah Tenaga Elektrik (nett) yang dijana oleh SESB & IPP bagi tahun 2016

Loji Penjanaan	GWh
SESB	861.4
IPP	1,881.9




2. Kecekapan Thermal bagi Loji-Loji Penjanaan SESB & IPP bagi tahun 2016

Loji Penjanaan	SESB	IPP
Loji Penjanaan Kitar Padu	25.8	39.2
Loji Penjanaan Enjin Diesel	27.0	36.7



3. Purata Faktor Kesediaan Setara Loji (AF) bagi Loji-Loji Penjanaan SESB & IPP bagi tahun 2016

Loji Penjanaan	SESB	IPP
Loji Penjanaan Kitar Padu	71.7	92.6
Loji Penjanaan Enjin Diesel	83.1	84.1
Loji Penjanaan Hidro - SESB sahaja	67.1	-
Purata AF	81.2	-



4. Purata Faktor Henti Tugas Tidak Terancang (UOF) bagi Loji-Loji Penjanaan SESB & IPP bagi tahun 2016

Loji Penjanaan	SESB	IPP
Loji Penjanaan Kitar Padu	12.3	2.7
Loji Penjanaan Enjin Diesel	11.3	14.8
Loji Penjanaan Hidro - SESB sahaja	19.2	-
Purata UOF	11.5	-

