



# State Generation Development and Small Clean Energy Resources

By

Syed Mohd Fauzi Shahab  
Director of Electricity Supply  
Ministry of Public Utilities Sarawak

## International Energy Regulatory Forum: Effective Regulation for a Sustainable Energy Industry

October 11<sup>th</sup>, 2011, JW Marriot Hotel, Kuala Lumpur



# Presentation Outline

- State Power Development Policy
- Power Sectors Development
- Small Renewable Energy Resources

# State Power Development Policy

- Ensuring availability of adequate, reliable, efficient, affordable and safe supply of electricity in the State which is managed in a sustainable manner

..con't

- Optimal and sustainable development of the power requirements
  - generation mix will be less dependent on fossil fuels especially oil and gas.
- Utilize indigenous hydro and coal resources
  - to meet future electricity demand to ensure long term competitive pricing and energy security.

## ....con't

- Development of hydro resources for trading of excess electricity beyond Sarawak
- Encourage small renewable energy development such as biomass, biogas, municipal wastes, wind, solar and mini-hydro as the fifth fuel resources under the nation's Fuel Diversification Policy

# Power Sectors Development

- Next two to three decades, rapid power demand growth due to
  - increased scale and pace of industrialization,
  - increased economic activities, and
  - higher living standards of population.
- Hydro and coal indigeneous resources will have an increasing role and opportunity as an energy provider.

## ...Con't

- Sarawak has huge geographical areas of rugged terrain and very low population density.
- Presently no transmission interconnection outside Sarawak.
- Electricity supply coverage has reached 82% of the total population of which rural population coverage is 64%.

## POWER DEMAND SECTORS

- Power demands identified to grow rapidly are;
  - Normal (organic) load in Sarawak.
  - Energy-intensive industries in Sarawak (SCORE).
  - Power export to neighbouring countries.
- Major drivers of State's power system development plan .

# Salient Features of Development Plan

The main elements of the plan:

- A 30-year strategic development plan
- Integrated and least-cost development of hydro as primary and coal as secondary energy resources for power generation
- Achieved a balanced generation mix of 70% hydro, 20% coal, 5% gas and 5% renewables.
- Coordinated development of transmission infrastructure in tandem with hydropower projects development.

# Projected Load Demand in Sarawak between 2010-2020


Demand in MW	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Organic loads	991	1050	1113	1180	1251	1326	1406	1490	1580	1674	1775
% contribution	92%	77%	58%	42%	36%	32%	33%	30%	32%	33%	34%
Energy Intensive & Export	90	307	807	1637	2217	2817	2817	3417	3417	3417	3417
% contribution	8%	23%	42%	58%	64%	68%	67%	70%	68%	67%	66%
<b>Total load demand</b>	<b>1081</b>	<b>1357.5</b>	<b>1920</b>	<b>2817</b>	<b>3468</b>	<b>4143</b>	<b>4223</b>	<b>4907</b>	<b>4997</b>	<b>5091</b>	<b>5192</b>
<b>Installed Capacity in MW</b>	<b>1250</b>	<b>1850</b>	<b>3752</b>	<b>4570</b>	<b>4570</b>	<b>5170</b>	<b>5170</b>	<b>5720</b>	<b>6024</b>	<b>7024</b>	<b>7294</b>
Reserve Margins (%)	14%	27%	49%	38%	24%	20%	18%	14%	17%	28%	29%

# Installation Capacity by Fuel Source (% of total)

<b>YEAR</b>	<b>2008</b>	<b>2010</b>	<b>2012</b>	<b>2015</b>	<b>2020</b>
Coal	24%	38%	16%	21%	18%
Gas	54%	46%	19%	11%	5%
Hydro	12%	9%	62%	66%	74%
Diesel	10%	7%	3%	1%	0%
Small Renewable	0%	0%	0%	1%	3%


# PRESENT STATE GRID SYSTEM

-  Existing 132KV AC line
-  Existing 275KV AC line
-  Under Construction 275KV AC line
-  Under Construction 132KV AC line
-  132KV AC substation
-  275KV AC substation
-  Hydro Power Plant
-  Coal Power Plant
-  Gas Power Plant



# GRID SYSTEM BY 2020

-  132KV AC line
-  275KV AC line
-  500 KV AC line
-  500kV AC Substation
-  132KV AC substation
-  275KV AC substation
-  Hydro Power Plant
-  Coal Power Plant
-  Gas Power Plant





D/S View of Murum Main Dam



Bakun HEP

# Small Clean (Renewable) Energy Resources

# MAIN SMALL RENEWABLE RESOURCES

- BIOMASS –
  - OIL PALM EFB (~800,000 HECTARE OF OIL-PALM)
  - WOODWASTES
- BIOGAS –
  - WASTES FROM INTEGRATED ANIMAL FARM
  - PALM OIL MILL EFFLUENCE (POME)
- SOLAR
- WIND
- MINI HIDROS

# ENABLERS TO ENCOURAGE

- ENCOURAGED, NOT IMPOSED :
  - SMALL RENEWABLE vs LARGE RENEWABLE HYDROS
  - GENERATION MIX - SUBSIDIZED GAS AND DIESEL NOT PREDOMINANT
  - COMPARATIVELY SMALL INSTALLED SYSTEMS (1850 MW) –CANNOT DRIVE SMALL RENEWABLE RESOURCES.
  - PRICE STABILITY OF ENERGY.
  - COMMERCIAL –DRIVEN
  - LICENSEE WILLINGNESS TO PURCHASE
- ENABLERS IN THE FOLLOWING AREAS:
  - REGULATORY
  - TECHNICAL REQUIREMENTS
  - PROCEDURAL

# ENABLERS - REGULATORY

- GENERATING LICENCE IF EXCEEDING 5kW.
  - FOR SOLAR OR WIND WITHOUT BATTERY STORAGE, NO LICENCE NEEDED IF NOT EXCEEDING 10 kW.
- IN COMMERCIAL BUILDINGS OR ABOVE 10 kWp, LICENCING REQUIRED:
  - SUBMISSION OF MAINTENANCE RECORD.
  - REGULATE ON THE SAFETY OF THE INSTALLATION AFTER METER POINT.

# ENABLER : TECHNICAL REQUIREMENTS


- LICENSEE POLICY ON SMALL RENEWABLE
  - 4% OF 2009 GRID CAPACITY (~1000MW)
- INTRODUCED NET-METERING DESIGN STANDARD FOR BIPV
  - LICENCEE (SESCO) BILL ON NET ENERGY USED
- INTERCONNECTION REQUIREMENTS FOR BIOMASS PLANTS (>5 MW)

# ENABLER : PROCEDURAL REQUIREMENTS


- MAINTENANCE ISSUES FOR SMALL GRID-CONNECTED PLANTS
  - ISOLATION POINTS
  - NOTICES
  - LIVE-LINE WORK
  - OPERATIONAL LIAISING



**Caution Notice at Pillar Door**



**Caution Notice at Disconnector Switch (Isolator) Outside PV Customer's Premises**



All Dimension in mm

**Caution Notice Fixed at Feeder Inside Pillar**



# SELF-GENERATION vs GRID CONNECTED

- OIL-PALM MILLS AND TIMBER-BASED MILLS
  - GENERALLY GENERATION FOR OWN USE
    - NEAR GRID LINES, SESCO'S SUPPLY AS STANDBY
    - WIN-WIN SITUATION FOR ALL
      - SESCO DEFER PLANT-UP AND GENERATION MIX : NO NEW 30MW GAS PLANT-UP BUT 270 MW COAL PLANT-UP.
      - AVOID OPEN BURNING OR STORAGES OF SUCH WASTES (RESIDUES)
      - ENVIRONMENTAL FRIENDLY

# SELF-GENERATION vs GRID CONNECTED

## CURRENT SITUATION:

- NEW MILLS NEAR GRID
  - ENCOURAGED TO CONSIDER SUPPLYING SURPLUS TO SESCO
    - INCORPORATE INTERCONNECTION REQUIREMENT AT EARLY DESIGN STAGE
- BIOMASS / BIOGAS GRID-CONNECTED
  - SECURING FUEL SUPPLY
  - COMPETITIVE USE OF FUEL SUPPLY
  - SYSTEM STUDIES UNDERTAKEN FOR INTERCONNECTION
  - PRICE AGREED WITH BUYER

# SMALL-RENEWABLE GENERATIONS DATA

SOURCES	No.	CAPACITY	REMARKS
<b>SOLAR-BIPV</b>			
Commercial	1	15.5 kWp	Grid-connected with net-metering
School / Training Institution	2	8.4 kWp	
Domestic	4	16.6 kWp	
<b>TOTAL:</b>	<b>7</b>	<b>40.5 kWp</b>	
<b>BIOMASS- OWN USE</b>			
Non-Grid Woodwastes	3	26,000 kW	Non-grid connected due to remote location
Non-Grid Oil Palm EFB	3	14,000 kW	Non-grid connected due to remote location.
Grid-Connected Woodwastes	7	43,000 kW	Grid-connected but SESCO supply for standby or to meet excess demand
<b>BIOMASS – POWER SALE</b>			
Oil-Palm EFB	4	45,000 kW	Power sale to grid.
<b>TOTAL:</b>	<b>17</b>	<b>128,000 kW</b>	