

PERKARA	ADAKAH MEMUASKAN?		CATATAN
SISTEM PENSTORAN GAS	Ya	Tidak	
Kawasan stor bebas daripada bau gas?			
Pintu berkunci dan disimpan oleh Orang Bertanggungjawab Gas?			
Sistem pengudaraan baik?			
Kawasan stor bebas daripada halangan di laluan keluar/masuk?			
Ada alat pemadam api disediakan?			
Ada papan tanda amaran?			
Kawasan stor terhindar daripada punca nyalaan?			
Kawasan stor terhindar daripada bahan mudah terbakar?			
SISTEM PERPAIPAN GAS	Ya	Tidak	
Bebas dari bau gas?			
Paip gas kukuh? (bebas retak / karat / hakisan)			
Paip gas berwarna kuning?			
Ada penanda arah aliran gas?			
Ada penyokong paip?			
Ada penanda lokasi paip gas bagi paip yang ditanam?			
Laluan keluar yang tidak digunakan telah dikedap?			
Sistem pengudaraan baik?			
PERALATAN GAS	Ya	Tidak	
Injap berfungsi dan mempunyai label BUKA-TUTUP?			
Alat pengatur berfungsi?			
Tolok tekanan berfungsi pada tekanan yang dibenarkan?			
PERKAKASAN GAS	Ya	Tidak	
Perkakas gas mempunyai label BUKA-TUTUP?			
Hos gas masih berkeadaan baik?			
Ada senarai semak harian aktiviti BUKA-TUTUP injap?			



#### **SURUHANJAYA TENAGA**

No. 12, Jalan Tun Hussein, Precint 2,  
62100 Putrajaya, Malaysia.

Tel : 03-8870 8500

Fax : 03-8888 8637

[www.st.gov.my](http://www.st.gov.my)



**ORANG BERTANGGUNGJAWAB**  
GAS RESPONSIBLE PERSON

## SENARAI TUGAS OB SCOPE OF WORK

1 Untuk memastikan bahawa talian paip gas itu kekal boleh dikenalpasti selama ia digunakan untuk menghantar gas. (Peraturan 62(2))

The responsible person or his representative shall ensure that the gas pipeline continues to be identifiable as long as it is used for conveying gas. (Regulation 62(2))

2 Sekiranya mengetahui atau mempunyai alasan untuk mengesyaki bahawa gas bocor kedalam premis, OB hendaklah dengan segera mengambil segala langkah yang munasabah untuk menyebabkan bekalan gas ditutup di tempat yang perlu untuk mencegah gas bocor lebih lanjut. (Peraturan 63(1))

If the responsible person or his representative knows or has reason to suspect that gas is escaping into the premises, he shall immediately take all reasonable steps to cause the supply of gas to be shut off at the necessary place to prevent further escape of gas. (Regulation 63(1))

3 Jika gas bocor ke dalam premis selepas bekalan gas ditutup atau jika terdapat bau gas yang berterusan, dan mendapat tahu tentang kebocoran atau bau itu, OB hendaklah dengan segera memberitahu Ketua Pengarah atau pemegang lesen tentang kebocoran atau bau itu. (Peraturan 63(2))

If gas continues to escape into the premises after the supply of gas has been shut off or when a smell of gas persists, the responsible person or his representative who discovers the escape or smell shall immediately inform or cause to be informed the Director General or the licensee of the escape or smell. (Regulation 63(2))

4 OB hendaklah bertanggungjawab untuk memastikan semua langkah-langkah keselamatan telah diambil tindakan untuk memastikan tiada membahayakan orang atau harta sebelum bekalan disambung semula. (Peraturan 64(1))

Where the supply of gas is shut off in any premises for safety reasons, it shall not be restored until all necessary steps are taken by the responsible person or his representative to ensure that gas can be resupplied without causing danger to a person or property. (Regulation 64(1))

5 OB hendaklah memastikan sistem disenggara dengan baik dan cekap dan standard keselamatan dipatuhi setiap masa bagi mencegah dari berlakunya bahaya. (Peraturan 128(2))

Responsible person must ensure a gas installation shall be maintained in good and efficient working order to ensure safety of persons and safety shall be observed at all times so as to prevent danger from arising. (Regulation 128(2))

## DEFINISI OB DEFINITION

"Berhubungan dengan mana-mana premis, ertiinya pemegang lesen atau pengguna atau penduduk premis, atau jika tiada pengguna atau penduduk, pemunya premis atau mana-mana orang yang diberikuasa oleh pengguna atau penduduk untuk menjaga talian paip gas atau pepasangan gas di dalam premis itu" (Peraturan-Peraturan Bekalan Gas 1997)

"In relation to any premises, means the licensee or consumer, or an occupier of the premises, or where there is no consumer or occupier, the owner of the premises or any person authorized by the consumer or occupier to be in charge of the gas pipeline or gas installation in the premises" (Gas Supply Regulations 1997)



6 OB hendaklah hadir semasa pemeriksaan dibuat dan memberikan apa-apa bantuan sebagaimana yang dikehendaki oleh Ketua Pengarah dalam notis pemeriksaan. (Peraturan 129(2))

The Director General shall require an inspection to be made by sending a notice in writing to the responsible person and that person shall attend the inspection and give any assistance as may be required by the Director General in the notice. (Regulation 129(2))

7 OB hendaklah menyimpan buku rekod penyenggaraan yang didalamnya ada menyatakan kerja-kerja penyenggaraan dan pemberian yang dijalankan atas pepasangan gas.(Peraturan 131(2))

Responsible person shall keep a maintenance record book in which any maintenance and repair work carried out on a gas installation is recorded. (Regulation 131(2))

8 OB adalah orang yang perlu diberitahu oleh orang kompeten mengenai perlunya pengubahan dan pemberian pada sistem bekalan gas.(Peraturan 134)

Where a competent person has reason to believe that there is a need for the alteration of, or the repair of a part of a supply system, the competent person shall immediately notify the responsible person of the matter. (Regulation 134)

9 Semasa kecemasan akibat kebocoran, orang kompeten perlu memberitahu OB mengenai kerja-kerja pemberian kekal yang perlu dibuat. (Peraturan 135)

Where gas is leaking from a part of the gas supply system, a competent person may make necessary emergency repairs and shall notify the responsible person of the permanent repairs that are necessary. (Regulation 135)

10 OB hendaklah mempastikan orang yang terlibat dalam kerja penyenggaraan yang berkaitan dengan pepasangan gas atau kelengkapan gas hendaklah dilindungi secukupnya dari bahaya. (Peraturan 137(2))

A person engaged in maintenance work in connection with a gas installation or gas equipment shall be adequately protected from danger and the responsibility for such protection shall be on the responsible person, his servant or agent, as the case may be. (Regulation 137(2))